

GOVT. OF ASSAM
OFFICE OF THE EXECUTIVE ENGINEER; PWD; NALBARI BUILDING DIVISION.
NALBARI.

No TB/BL/DM/699/07-08/PT-III/ 112A

Dtd. 23-6-18

BUILDING SAFETY CERTIFICATE.

This is to Certify that the building constructed for (i) Academic Block for Class -I to X and (ii) Pre-Primary Block for Class -Nursery to UKG by the VIDYANCHAL THE SCHOOL at Opposite Barkura Rail Gate; Vill- Haripur, N.H.-27(Old N.H.-31) in Nalbari District of Assam in the year 2016 as per inspection report (enclosed) inspected on 27/06/2018 are as follows –

1. Buildings has been structurally designed & constructed as per BIS Code relevant for building construction in Seismic Zone- V.
2. Academic Block for Class - I to X with provision of (G+2), only a part of the Ground floor measuring Plinth area of 1929.40 Sqm. with 13 nos. class room has been completed.
3. Pre-Primary Block for Class - Nursery to UKG with provision of R.C.C. Assam Type provision measuring Plinth area of 717.80 Sqm. with 5 nos. class room has been completed.
4. Separate Toilet for boys & Girls has been provided both in the building.
5. Passage, Stairs, Ramp etc. has been provided of adequate width.
6. Fire fighting measures like Fire Extinguisher, Hydrant System and Fire indicator has been properly installed.
7. Electrical fittings has been made of PVC recessed Conduit System in the buildings.

The completed portions of the aforesaid buildings are fit for the intended purpose of use.


Assistant Engineer, P.W.D.
Nalbari Building Division
Nalbari


Asst. Executive Engineer, PWD
Nalbari Building Sub-Division
Nalbari


Executive Engineer, P.W.D.
Nalbari Building Division
Nalbari